



# Fire Safe Test API 6FA Certificate

Office: **Barcelona**

Date: **June 2<sup>nd</sup>, 2009**

This certificate is issued to

## **PICTOR VALVES, S.L.**

*to certify that the undersigned Surveyor to this Society did attend at their premises in ESPARREGUERA Barcelona (SPAIN) on April 22<sup>th</sup>, 2009, for the purpose of witnessing the FIRE SAFE TESTS on*

*type of valve:*

**MANUAL OPERATED GATE VALVE FULL BORE BI-DIRECTIONAL  
2" CLASS 300 lb**

**REF 2168**

*The valve was found to comply with the requirements specified in:*

**API-6FA Standard, 3rd Edition (April 1999), API Spec 6D**

*Results, witnessed by the undersigned, are stated on the manufacturer's Fire Safe Test Report N° 001 and found **satisfactory***

*According to the specification and tests results, the following class and valve sizes are qualified:*

**NPS**

**CLASS RATING**

**2"; 2½"; 3"; 4"**

**150, 300**

**DN 50, DN 65; DN 80; DN 100**

**PN 25; PN 40**

Certificate

Annex/ attachments  
- Manufacturers Test Report N° 1  
- Drawing N°: 200863

Juan Carlos Ortega  
Surveyor to Lloyd's Register EMEA

A member of the Lloyd's Register Group



Lloyd's Register, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register Group'. The Lloyd's Register Group assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register Group entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



# Fire Safe Test API 6FA Certificate

Office: **Barcelona**

Date: **June 2<sup>nd</sup>, 2009**

This certificate is issued to

## **PICTOR VALVES, S.L.**

*to certify that the undersigned Surveyor to this Society did attend at their premises in ESPARREGUERA Barcelona (SPAIN) on April 24<sup>th</sup>, 2009, for the purpose of witnessing the FIRE SAFE TESTS on*

*type of valve:*

**MANUAL OPERATED GATE VALVE FULL BORE BI-DIRECTIONAL  
3" CLASS 300 lb**

**REF 2168**

*The valve was found to comply with the requirements specified in:*

**API-6FA Standard, 3rd Edition (April 1999), API Spec 6D**

*Results, witnessed by the undersigned, are stated on the manufacturer's Fire Safe Test Report N° 002 and found **satisfactory***

*According to the specification and tests results, the following class and valve sizes are qualified:*

<b>NPS</b>	<b>CLASS RATING</b>
<b>3"; 4", 6"</b>	<b>300, 400, 600</b>
<b>DN 80, DN 100; DN125</b>	<b>PN 50; PN 64, PN110</b>

- Annex/ attachments**  
- **Manufacturers Test Report N° 2**  
- **Drawing N°: 200864**

  
Juan Carlos Ortega  
Surveyor to Lloyd's Register EMEA  
A member of the Lloyd's Register Group



Lloyd's Register, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register Group'. The Lloyd's Register Group assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register Group entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



# Fire Safe Test API 6FA Certificate

Office: **Barcelona**

Date: **June 2<sup>nd</sup>, 2009**

This certificate is issued to

## **PICTOR VALVES, S.L.**

*to certify that the undersigned Surveyor to this Society did attend at their premises in ESPARREGUERA Barcelona (SPAIN) on April 28<sup>th</sup>, 2009, for the purpose of witnessing the FIRE SAFE TESTS on*

*type of valve:*

**MANUAL OPERATED GATE VALVE FULL BORE UNIDIRECTIONAL  
6" CLASS 300 lb**

**REF 2168**

*The valve was found to comply with the requirements specified in:*

**API-6FA Standard, 3rd Edition (April 1999), API Spec 6D**

*Results, witnessed by the undersigned, are stated on the manufacturer's Fire Safe Test Report N° 003 and found **satisfactory***

*According to the specification and tests results, the following class and valve sizes are qualified:*

**NPS**

**CLASS RATING**

**6", 8", 10", 12"**

**300, 400, 600**

**DN 150, DN 200; DN 250, DN 300**

**PN 50; PN 64, PN110**

Certificate


Annex/ attachments  
- Manufacturers Test Report N° 3  
- Drawing N°: 200862

  
Juan Carlos Ortega  
Surveyor to Lloyd's Register EMEA



A member of the Lloyd's Register Group

Lloyd's Register, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register Group'. The Lloyd's Register Group assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register Group entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



# Fire Safe Test API 6FA Certificate

Office: **Barcelona**

Date: **June 2<sup>nd</sup>, 2009**

This certificate is issued to

## **PICTOR VALVES, S.L.**

*to certify that the undersigned Surveyor to this Society did attend at their premises in ESPARREGUERA Barcelona (SPAIN) on may 6<sup>th</sup>, 2009, for the purpose of witnessing the FIRE SAFE TESTS on*

*type of valve:*

**MANUAL OPERATED GATE VALVE FULL BORE UNIDIRECTIONAL  
12" CLASS 300 lb**

**REF 2168**

*The valve was found to comply with the requirements specified in:*


**API-6FA Standard, 3rd Edition (April 1999), API Spec 6D**


*Results, witnessed by the undersigned, are stated on the manufacturer's Fire Safe Test Report N° 004 and found **satisfactory***

*According to the specification and tests results, the following class and valve sizes are qualified:*

<b>NPS</b>	<b>CLASS RATING</b>
<b>12" through 24"</b>	<b>300, 400, 600</b>
<b>DN 300 through DN 600</b>	<b>PN 50; PN 64, PN110</b>

**Annex/ attachments**  
- **Manufacturers Test Report N° 4**  
- **Drawing N°: 200865**

  
Juan Carlos Ortega  
Surveyor to Lloyd's Register EMEA

  
Lloyd's Register España S.A.  
Barcelona  
Lloyd's Register

A member of the Lloyd's Register Group

Lloyd's Register, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register Group'. The Lloyd's Register Group assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register Group entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.